



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
LANSING



LIESL EICHLER CLARK
DIRECTOR

November 21, 2019

VIA E-MAIL

Karegnondi Water Authority
4001 Fisher Road
Jeddo, Michigan 48032

WSSN: 03563

Dear Water Supply Owner/Operator:

SUBJECT: Karegnondi Water Authority
2019 Monthly Per- and Polyfluoroalkyl Substances (PFAS) Results

Karegnondi Water Authority is participating in the Michigan Department of Environment, Great Lakes, and Energy (EGLE) (formerly the Michigan Department of Environmental Quality) state-funded monthly PFAS monitoring effort for community water supplies utilizing surface water as a source, that were tested during the statewide PFAS sampling effort in 2018. The most recent results for PFAS samples collected from Karegnondi Water Authority, WSSN # 03563 (water supply) on the date(s) indicated are included below. A copy of the laboratory report is enclosed for your review.

Date Collected	Sampling Location	PFOS + PFOA (parts per trillion (ppt))	LHA (ppt) PFOS + PFOA	Total Tested PFAS (ppt)
8/29/2019	IN001 - Influent ²	ND	70	ND

ND – The parameter was not detected based on the laboratory’s analytical report.
See Official lab results for test method used. ¹US EPA Method 537. ²PFAS Isotope Dilution Method.

Currently, there is no regulatory drinking water standard for any of the PFAS chemicals. However, in May 2016, the United States Environmental Protection Agency (USEPA) established a non-regulatory Lifetime Health Advisory (LHA) for two of these chemicals, perfluorooctanesulfonic acid (PFOS) and perfluorooctanoic acid (PFOA). The LHA for PFOS and PFOA is 70 ppt combined, or individually if only one of them is present.

Your water supply may have returned results greater than non-detect (ND) for one or more of the PFAS analytes tested (other than PFOS or PFOA). Neither EGLE nor the USEPA currently have any guidance values for these other analytes. If additional guidance and/or comparison values are developed for PFOS, PFOA, or other PFAS chemicals in the future, we may reevaluate the recommendations below.

The concentrations of PFOS and PFOA in these samples are below the USEPA LHA of 70 ppt. We provide the following recommendations:

1. Inform the public as soon as possible of these sample results through posting on your Web site or other means. EGLE, in collaboration with the Michigan Department of Health and Human Services (MDHHS), has developed a toolkit containing communication templates to help notify the consumers of your water supply on the presence of PFAS in the drinking water and the response measures that are being initiated. This is a resource available to you if you choose and can be modified to fit your needs. The toolkit is available at www.Michigan.gov/PFASResponse; click on “news and education.”
2. Evaluate options to modify operations to reduce PFAS in the water supply should levels approach the existing LHA. For example, this could be accomplished by minimizing use of wells with elevated PFAS levels or through the installation of treatment technology capable of reducing PFAS prior to distribution.
3. Please continue with your regularly scheduled monitoring.

The results of the 2019 sampling will be posted online on the Michigan PFAS Action Response Team (MPART) Web site within 48 hours of this notification. The results will be found online by going to the MPART Web site address listed below; click on “Testing and Treatment,” scroll down to “Drinking Water,” and select “Statewide Testing Initiative.”

For information on PFOS, PFOA, and other PFAS, including possible health outcomes, you may visit these Web sites:

- **State of Michigan MPART** Web site serving as the main resource for public information on PFAS contamination in Michigan: www.Michigan.gov/PFASResponse
- **USEPA** Web site including basic information, USEPA actions, and links to informational resources: <http://www.epa.gov/pfas>
- **ATSDR** Web site including health information, exposure, and links to additional resources: www.atsdr.cdc.gov/pfas

To speak to a MDHHS toxicologist, call toll-free at 1-800-648-6942.

Thank you for your continued collaboration with this investigation. The ongoing partnership between EGLE and Michigan’s public water supplies plays an integral role in the state’s continued efforts to ascertain and address the incidence of PFAS in drinking water for Michiganders.

Karegnondi Water Authority

Page 3

November 21, 2019

If you have any questions concerning this sampling, please contact me at the telephone number below; by email at EGLE-PFAS-DrinkingWater@Michigan.gov; or by mail at EGLE-Drinking Water and Environmental Health Division, P.O. Box 30817, Lansing, Michigan 48909-8311.

Sincerely,

Lois Elliott Graham

Lois Elliott Graham, R.S., M.S.A.
Drinking Water and Environmental Health
Division
810-730-8674

Enclosure

cc: Mr. Jim Henry, Genesee County Health Department
Mr. Steven Crider, Supervisor, Drinking Water Unit, MDHHS
Mr. Dennis Eagle, EGLE
Mr. Bob London, EGLE